

PLAN 9

INGENIERIE FLUIDES

ET ENVIRONNEMENT


ECONOMIE - OPC

10, RUE DE SERRE

54 000 N A N C Y


TEL : 03 83 31 77 72

www.plan-9.fr



Bilan Mesures Externat du Collège Georges CHEPFER	2018
---	------

	PC+Ventil	ECLAIRAGE	CH + BSO	ECS
Niveau 0	7836	7829	3775	292
Niveau 1	3983	3919	1593	110
Niveau 2	2942	2599	1385	58
Niveau 3	3922	3300	408	5
Niveau 4	12001			



Chaufferie			61439		61439	kWh
Total Elec	30684	17647	7160.800452	465	55956.8005	kWh
Consommations	10.69	6.15	23.89	0.16	40.89	kWh/m²

SRE	2 871	m²
Conso Totale EP	74.45	kWhEP/m²
Conso RT 2005	46.49	kWhEP/m²
Coût	8 668 €	
Coût	3.02 €	/m²

Température de reprise de 21 °C

26/02/2019